

“जल संचय-जीवन संचय”



कार्यालय सहायक अभियन्ता, उत्तराखण्ड जल संस्थान
सहसपुर (देहरादून)



ई-मेल :- spursubdiv@gmail.com

दूरभाष :- 0135-2983939

पत्रांक : 161 / सहसपुर / 2023-24

दिनांक: 29-5-23

सेवा में,

प्रधानाध्यापक
द इण्डियन पब्लिक स्कूल
मृत्युंजय धाम, पो0ओ0 राजावाला
देहरादून।

विषय:- सी0बी0एस0ई0 सम्बद्धता नवीनीकरण हेतु प्रमाण पत्र के सम्बन्ध में।

महोदय,

उपरोक्त विषयक, कृपया अपने पत्र सं0 011/CBSE/APP-AFF/IPS-2023 दिनांक 26-05-2023 का सन्दर्भ ग्रहण करने का कष्ट करेंगे, जिसमें आपके द्वारा द इण्डियन पब्लिक स्कूल, मृत्युंजय धाम, राजावाला में सी0बी0एस0ई0 सम्बद्धता नवीनीकरण प्रमाण पत्र हेतु अनुरोध किया गया है, जिस क्रम में संलग्न वॉटर क्वालिटी टैस्ट रिपोर्ट के आधार पर प्रमाण पत्र निर्गत कर आपको प्रेषित किया जा रहा है।

संलग्न : प्रमाण पत्र एवं वॉटर क्वालिटी टैस्ट रिपोर्ट।

भवदीय


सहायक अभियन्ता





0229013428
DA W.C. Dehradun

PROFORMA FOR SAFE DRINKING WATER AND SANITARY**CONDITION CERTIFICATE**No. 161/Sahaspur/2023-24Dated: 29-05-23

It is certified that an inspection team headed by Mr. B.S. Rawat, Assistant Engineer from Uttarakhad Jal Sansthan, Sahaspur inspected the "The Indian Public School, Mritunjay Dham P.O. Rajawala via Premnagar Dehradun" on 26-05-23 and found that the "The Indian Public School, Mritunjay Dham P.O. Rajawala via Premnagar Dehradun" has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of 02 Years.

Signature with Seal: Name : B.S. Rawat सहायक अभियन्ताDesignation : A.E. उत्तराखण्ड जल संस्थान

सहसपुर





**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**



TC-10477

Test Report ID: 239/UJS/DLWQTML/2023-24

ULR No.:TC10477230000000084F

Dated: 27/05/2023

TEST REPORT

Name and Address of Organization/ Customer	The Indian Public School, Dehradun		
Product Description	Drinking Water	Sample Description	One Water Sample collected from The Indian Public School
Reference Sample Identification:	DLWQTML/UJS/2023-84		Date of Start of Analysis: 26/05/2023
Date and Time of Sample Received: 26/05/23 & 10:30 AM	Sample Collected by:		Date of End of Analysis: 27/05/2023
	Customer:		

S N	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH at 25°C	7.75	6.5 to 8.5	No Relaxation	IS 3025 (Part 11) 1983, RA: 2017: Electrometric method
2.	Total Dissolved Solids (TDS), mg/L, Max	108.8	500	2000	IS 3025 (Part 16), 1984 RA: 2017: Gravimetric Method
3.	Turbidity, NTU, Max	0.92	1	5	IS 3025 (Part 10), 1984, RA:2017: Nephelometric Method
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	20	200	600	IS 3025 (Part 23), 1986 RA: 2019 Titrimetric Method
5.	Total Hardness (as CaCO ₃), mg/L, Max	56	200	600	IS 3025 (Part 21), 2009 RA:2019, (a) EDTA Titrimetric Method
6.	Calcium as Ca, mg/l	8.8	75	200	IS 3025 (Part 21), 2009 RA:2019 (a) EDTA Titrimetric Method
7.	Chloride, mg/L, Max	11.76	250	1000	IS 3025 (Part 32): 1988, RA: 2019 Argentometric Method
8.	Magnesium as Mg, mg/l	8.26	30	100	APHA 23 rd -3500-Mg Method B:2017 (Calculation Method)
9.	Colour, Hazen, Max	Less than 01	5	15	IS 3025 (Part 4): 2021Platinum Cobalt (Visual Comparison)
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2018

Vikas Kandari
27/05/23
Vikas Kandari
Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

-End of Report -

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
- The results apply to the sample as received

Mansi



Shel





**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

Test Report ID: 239A/UJS/DLWQTML/2023-24

Dated: 27/05/2023

TEST REPORT

Name and Address of Organization/ Customer	The Indian Public School, Dehradun		
Product Description	Drinking Water	Sample Description	One Water Sample collected from The Indian Public School
Reference Sample Identification:	DLWQTML/UJS/2023-84		Date of Start of Analysis: 26/05/2023
			Date of End of Analysis: 27/05/2023
Date and Time of Sample Received: 26/05/23 & 10:30 AM	Sample Collected by:		Customer.

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	Fluoride, mg/L, Max	0.12	1.0	1.5	APHA 23rd Ed. 4500-F-D: 2017: SPADNS Method
2	Nitrate, mg/L, Max	1.6	45	No Relaxation	APHA 23rd Ed. 4500-NO ₃ -B-2017: Ultraviolet Spectrophotometric Screening Method
3	Sulfate, mg/L, Max	28	200	400	APHA 23rd Ed. 4500-SO ₄ -E: 2017: Turbidimetric Method
4	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
5	E. coli, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B

Mangit



DLWS



Vikash Kandari
27/05/23
(Dr. Vikash Kandari)
Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

- * End of Report *
- The results listed refer only to tested sample and applicable parameters.
 - This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
 - The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.
 - The results apply to the sample as received